



## **3070 Installation Kit**

- 1- Flow Meter (F-41000LN-16)
- 1- 1 ½" Filter (1-1/2-60-F)
- 1- 1x1 ½" Male Adapter (436-133)
- 2-1" Street Elbow m x fpt (412-010)
- 1- 1 ½" Gate Valve (GVG-1500-S)
- 1- 1 ½" Flap Check (S1720C15)
- 1-Pump Manual
- 1- 3070 Manual
- 8- ⅜" Jam nuts
- 1- ⅜" Shoulder Bolts-2" long

## **Installation Instructions**

1. Place the chlorination system in a location near the place of application.
2. Level the system. This is important for proper chlorine delivery.
3. Connect the inlet flow meter assembly to the solution tank. The parts were shipped separately to prevent breakage in shipping.
4. Connect the inlet water supply with 1-1/2" PVC pipe or hose. Include an isolation valve in the line.
5. Connect the discharge assembly to the pump using a section of 1-1/2" pipe. (The parts were shipped loose to prevent breakage in shipment.)
6. Connect the discharge piping from the feeder to the chlorine application point with 1-1/2" PVC pipe or hose. Include an isolation valve in the line.
7. Plug the power cord into an 120v receptacle.
8. If a chemical controller is utilized, plug the controller cord into the controller's 120v switched output.

**NOTE: IF A HIGH PRESSURE WEBTROL PUMP IS ORDERED, A LARGER CAPACITY PUMP CONTACTOR IS INSTALLED IN THE ELECTRICAL BOX AND NO CORD/PLUG IS PROVIDED AS A 25 AMP CIRCUIT IS REQUIRED.**

To view the full 3070 Manual, please visit the Resource Center at [www.puraquaproducts.com](http://www.puraquaproducts.com)