

Chlorinator Capacity Required per State Health Code

State	Indoor			Outdoor	
	ppm/day	# AvCl/day per 10,000 gal	Circulation water Conc in PPM	ppm/day	# AvCl/day per 10,000 gal
AK	none	none	none	none	none
AL	8	0.67	2	8	0.67
AR	15	1.25	3.75	15	1.25
AZ	none	none	none	none	none
CA	36	3	9	36	3
CO	36	3	9	36	3
CT	36.72	3.06	9.18	36.72	3.06
DE	20	1.67	5	40	3.33
FL	24	2	6	24	2
GA	36	3	9	36	3
HI	5.76	0.48	1.44	11.52	0.96
IA	none	none	none	none	none
ID	36	3	9	36	3
IL	12	1	3	32	3
IN	12	1	3	32	3
KS	none	none	none	none	none
KY	12	1	3	32.5	3
LA	5.76	0.48	1.44	11.52	0.96
MA	8	0.67	2	36	3.00
MD	30	2.5	7.5	30	2.5
ME	none	none	none	none	none
MI	30	2.5	7.5	30	2.5
MN	36	3	9	36	3
MO	40.8	3.4	10.2	40.8	3.4
MS	none	none	none	none	none
MT	24	2	6	24	2
NC	11.5	0.96	2.875	11.5	0.96
ND	40	3.33	10	40	3.33
NE	none	none	none	none	none
NH	30	2.5	7.5	30	2.5
NJ	10	0.83	2.5	10	0.83
NM	10	0.83	2.5	10	0.83
NV	12	1	3	36	3
NY	40.3	3.36	10	40.3	3.36
OH	36	3	9	36	3
OK	18	1.5	4.5	18	1.5
OR	none	none	none	none	none
PA	30.3	2.53	7.575	30.3	2.53
RI	36.7	3.06	9.175	36.7	3.06
SC	24	2	6	24	2
SD	36.9	3.08	9.225	36.9	3.08
TN	11.52	0.96	2.88	11.52	0.96
TX	11.52	0.96	2.88	11.52	0.96
UT	36	3	9	36	3
VA	24	2	6	24	2
VT	11.52	0.96	2.88	11.52	0.96
WA	12	1	3	36.9	3
WI	11.52	0.96	2.88	20	1.67
WV	11.52	0.96	2.88	11.52	0.96
WY	8	0.67	2	8	0.67

Circulation water Conc in PPM
none
2
3.75
none
9
9
9.18
10
6
9
2.88
none
9
8
8
none
8.125
2.88
9
7.5
none
7.5
9
10.2
none
6
2.875
10
none
7.5
2.5
2.5
9
10
9
4.5
none
7.575
9.175
6
9.225
2.88
2.88
9
6
2.88
9.225
5
2.88
2